



NOTES:

1. WHERE POSSIBLE, PIV SHALL BE LOCATED ON THE FIRELINE BETWEEN THE R/W LINE AND THE FDC.
2. FIRE MARSHALL SHALL APPROVE FDC LOCATION.
3. MUST BE TESTED BY A WASHINGTON STATE DOH CERTIFIED BACKFLOW ASSEMBLY TESTER UPON INSTALLATION.



City of Bellevue

WATER UTILITY

TITLE

OUTSIDE DCVA INSTALLATION FOR
 3" AND LARGER COMMERCIAL FIRE
 SPRINKLER SYSTEMS