


- NOTES:
1. ALL PIPE SHALL BE BRASS BEYOND GATE VALVE.
 2. ALL ASSEMBLIES SHALL BE LOCATED IN STREET UNLESS OTHERWISE NOTED.
 3. WHEN INSTALLED OUTSIDE PAVED AREAS, INSTALL VALVE MARKER POST PER STANDARD DETAIL NO. W-14 AND FIELD LOCATE ADJACENT TO METER BOX PAINTED WITH TWO COATS OF RUSTOLEUM HIGH GLOSS WHITE PAINT.

	<h1>City of Bellevue</h1>	WATER UTILITY
	TITLE <h2>2" BLOW-OFF ASSEMBLY</h2>	
JANUARY 2025		NO SCALE
		NO. <u>W-15</u>