



NOTES:

1. FIRE MARSHAL SHALL APPROVE FDC AND/OR PIV LOCATION IF LESS THAN 50FT. FROM STRUCTURE.
2. TESTING IS REQUIRED BY A WASHINGTON STATE DEPARTMENT OF HEALTH CERTIFIED BACKFLOW ASSEMBLY TESTER UPON INSTALLATION AND ANNUALLY THEREAFTER. ASSEMBLY TO BE MAINTAINED BY OWNER.



City of
Bellevue

WATER UTILITY

TITLE
 OUTSIDE DCVA INSTALLATION FOR
 1 1/2" & 2" COMMERCIAL FIRE
 SPRINKLER SYSTEMS
 NO. W-39