



NOTES:

1. J-BOLT OR ALL THREADED MINIMUM ROD DIAMETER:
 - 4" PIPE: 5/8" DIAMETER
 - 6" PIPE: 5/8" DIAMETER
 - 8" PIPE: 5/8" DIAMETER
 - 10" PIPE: 5/8" DIAMETER
 - 12" PIPE: 7/8" DIAMETER
 - 16" PIPE: 7/8" DIAMETER
 - 20" PIPE: 1-1/4" DIAMETER
 - 24" PIPE: 1-1/4" DIAMETER
2. TIGHTEN TOP NUTS TO TENSION BOLTS.
3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.



City of
Bellevue

WATER UTILITY

TITLE

PIPE CLAMP AND ANCHOR RODS
FOR CONCRETE BLOCKING