



NOTES:

1. ALL STEEL PARTS MUST BE GALVANIZED AND ASPHALT COATED (TREATMENT 1 OR BETTER).
2. CONTRACTOR TO VERIFY DIMENSIONS.
3. TO BE USED IN DETENTION PONDS AND PIPES GREATER THAN 18" DIAMETER.



City of
Bellevue

STORM AND SURFACE
WATER UTILITY

TITLE

TRASH RACK/DEBRIS BARRIER