




NOTES:

1. J-BOLT OR ALL THREADED MINIMUM ROD DIAMETER:

- 4" PIPE: 5/8" DIAMETER
- 6" PIPE: 5/8" DIAMETER
- 8" PIPE: 5/8" DIAMETER
- 10" PIPE: 5/8" DIAMETER
- 12" PIPE: 7/8" DIAMETER
- 16" PIPE: 7/8" DIAMETER
- 20" PIPE: 1-1/4" DIAMETER
- 24" PIPE: 1-1/4" DIAMETER

2. TIGHTEN TOP NUTS TO TENSION BOLTS.

3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.



City of
Bellevue

WATER UTILITY

TITLE

PIPE CLAMP AND ANCHOR RODS
FOR CONCRETE BLOCKING