



NOTES:

1. MAXIMUM WIDTH OF TRENCH AT TOP OF PIPE
  - \* 30" FOR PIPE UP TO AND INCLUDING 18" NOMINAL DIAMETER.
  - \* O.D. PLUS 16" FOR PIPE LARGER THAN 18" NOMINAL DIAMETER.
2. EXCAVATIONS OVER 4' DEEP SHALL COMPLY WITH THE SAFETY STANDARD DESCRIBED IN CHAPTER 296-155-PART N OF THE WAC.
3. SEE "BACKFILLING TRENCHES" IN CHAPTER D8 OF THE ENGINEERING STANDARDS FOR ADDITIONAL CONSTRUCTION REQUIREMENTS.



City of  
Bellevue

STORM AND SURFACE  
WATER UTILITY

TITLE

TYPICAL TRENCH DETAIL