



NOTES:

1. J-BOLT OR ALL THREADED ROD DIAMETER:
  - PIPE DIAMETER LESS THAN OR EQUAL TO:
  - 8" PIPE: 3/4" DIAMETER
  - 10" PIPE: 1" DIAMETER
  - 12" PIPE: 1-1/8" DIAMETER
  - 16" PIPE: 1-1/4" DIAMETER
  - 20" PIPE: 1-3/8" DIAMETER
  - 24" PIPE: 1-5/8" DIAMETER
2. TIGHTEN TOP NUTS TO TENSION BOLTS.
3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.



City of  
Bellevue

WATER UTILITY

TITLE

PIPE CLAMP AND ANCHOR RODS  
FOR CONCRETE BLOCKING