



- NOTES:**
1. CONTRACTOR TO VERIFY BOLT PATTERN WITH CABINETS.
  2. FOR CONDUIT LOCATION, SEE SERVICE CABINET DETAIL, STD. DWG. SL-220-1.
  3. 1-1" CONDUIT FOR CONNECTION OF BARE #4 COPPER WIRE TO 8' GROUND ROD IN GROUND MONUMENT LOCATED A MIN. 6" FROM THE SERVICE FOUNDATION.

SERVICE CABINET FOUNDATION DETAIL

DRAWING NUMBER	SL-211-1
SCALE	NONE
REVISION DATE	4/21
DEPARTMENT	TRANS

SERVICE CABINET FOUNDATION DETAIL

