



NOTES:

1. J-BOLT OR ALL THREADED MINIMUM ROD DIAMETER:
  - 4" PIPE: 5/8" DIAMETER
  - 6" PIPE: 5/8" DIAMETER
  - 8" PIPE: 5/8" DIAMETER
  - 10" PIPE: 5/8" DIAMETER
  - 12" PIPE: 7/8" DIAMETER
  - 16" PIPE: 7/8" DIAMETER
  - 20" PIPE: 1-1/4" DIAMETER
  - 24" PIPE: 1-1/4" DIAMETER
2. TIGHTEN TOP NUTS TO TENSION BOLTS.
3. TIGHTEN LOWER NUTS TO COMPRESS CLAMP SNUG.



City of  
Bellevue

WATER UTILITY

TITLE

PIPE CLAMP AND ANCHOR RODS  
FOR CONCRETE BLOCKING