



NOTES:

1. SEE SECTION 3.4.1.1 OF THE DESIGN MANUAL FOR REQUIRED SIDEWALK AND LANDSCAPED PLANTER STRIP WIDTHS. SEE STD. DWG. RC-240-1 FOR ASPHALT DETAIL ADJACENT TO LANDSCAPED STRIP AND STD. DWG. SW-130-1 FOR SOIL PREPARATION.
2. RIGHT-OF-WAY AND PAVEMENT WIDTHS SHOWN ARE TYPICAL RANGES. REQUIRED WIDTHS WILL BE SPECIFIED BY THE ENGINEER.
3. REQUIRED SUBGRADE MATERIALS (GRAVEL BORROW, ETC.) AND THICKNESS WILL BE BASED ON A GEOTECHNICAL REPORT/SOIL ANALYSIS UNLESS OTHERWISE SPECIFIED BY THE REVIEW ENGINEER.
4. MINIMUM PAVEMENT THICKNESS SHALL BE 2 INCHES OF HOT MIX ASPHALT CLASS ½" PG 58H-22 OVER 4 INCHES OF HOT MIX ASPHALT CLASS ½" PG 58H-22. IF REQUIRED, ADDITIONAL PAVEMENT THICKNESS WILL BE SPECIFIED BY THE ENGINEER.
5. SIDEWALK AT DRIVEWAYS AND PRIVATE ROAD APPROACHES SHALL BE 6 INCHES THICK.
6. ONE FOOT SETBACK DISTANCE REQUIRED FROM ALL SLOPED AREAS AS SHOWN.
7. CROSS SLOPE 2% MAXIMUM, 0.5% MINIMUM. USE 1.5% UNLESS OTHERWISE APPROVED BY THE ENGINEER.
8. CROSS SLOPE 2% UNLESS OTHERWISE APPROVED BY THE ENGINEER.



TYPICAL LOCAL STREET

DRAWING NUMBER	RC-110-1
SCALE	NONE
REVISION DATE	2/24
DEPARTMENT	TRANS