



NOTES:

1. SEE SECTION 3.4.1.1 OF THE DESIGN MANUAL FOR REQUIRED SIDEWALK AND LANDSCAPED PLANTER STRIP WIDTHS. SEE STD. DWG. RC-240-1 FOR ASPHALT DETAIL ADJACENT TO LANDSCAPED STRIP AND STD. DWG. SW-130-1 FOR SOIL PREPARATION.
2. RIGHT-OF-WAY AND PAVEMENT WIDTHS SHOWN ARE TYPICAL RANGES. REQUIRED WIDTHS WILL BE SPECIFIED BY THE ENGINEER.
3. REQUIRED SUBGRADE MATERIALS (GRAVEL BORROW, ETC.) AND THICKNESS WILL BE BASED ON A GEOTECHNICAL REPORT/SOIL ANALYSIS UNLESS OTHERWISE SPECIFIED BY THE REVIEW ENGINEER.
4. CSBC (4" MIN.) SHALL BE COMPACTED TO 95% MAX. DENSITY.
5. MINIMUM PAVEMENT THICKNESS SHALL BE 2 INCHES OF HOT MIX ASPHALT CLASS ½" PG 58H-22 OVER 4 INCHES OF HOT MIX ASPHALT CLASS ½" PG 58H-22. IF REQUIRED, ADDITIONAL PAVEMENT THICKNESS WILL BE SPECIFIED BY THE ENGINEER.
6. SEE SECTION 3.4.1.1 OF THE DESIGN MANUAL FOR THICKNESS OF SIDEWALK AT DRIVEWAY APPROACHES.
7. ONE FOOT SETBACK DISTANCE REQUIRED FROM ALL SLOPED AREAS AS SHOWN.
8. CROSS SLOPE 2% MAXIMUM, 0.5% MINIMUM. USE 1.5% UNLESS OTHERWISE APPROVED BY THE ENGINEER.
9. CROSS SLOPE 2% UNLESS OTHERWISE APPROVED BY THE ENGINEER.



TYPICAL LOCAL STREET

DRAWING NUMBER	RC-110-1
SCALE	NONE
REVISION DATE	1/25
DEPARTMENT	TRANS