

- 3. LIGHTING RECEPTACLE CLEAR WORKING SPACE SHALL HAVE A MINIMUM 30-INCH WIDTH PER NEC 110.26(A)2.
- 4. LIGHTING RECEPTACLE SHALL BE LISTED AND MARKED WITH THE MANUFACTURER'S NAME OR IDENTIFICATION AND VOLTAGE AND AMPERE RATINGS PER NEC 406.3.
- 5. LIGHTING RECEPTACLE SHALL HAVE A METALLIC, LOCKABLE INTERMATIC WP1010MXD COVER OR APPROVED EQUAL.
- 6. CONDUIT FOR OUTLET SHALL BE IN SAME TRENCH AS STREET LIGHTING CONDUIT.



HOLIDAY LIGHTING RECEPTACLE IN LANDSCAPED PLANTER STRIP

DRAWING NUMBER	SL-370-1
SCALE	NONE
REVISION DATE	1/25
DEPARTMENT	TRANS