



NOTES:

1. LANDSCAPE PLAN IS REQUIRED TO BEAUTIFY OR SCREEN POND.
2. 6' MINIMUM, 15' MINIMUM FOR VEHICLE ACCESS TO CONTROL STRUCTURE.
3. SHEAR GATE REQUIRED FOR ALL SYSTEMS TO BE MAINTAINED BY THE CITY.
4. CAPACITY OF OUTLET PIPE MUST BE EQUAL TO OR GREATER THAN DISCHARGE DURING EMERGENCY OVERFLOW CONDITION. 8-INCH MINIMUM DIAMETER.



City of Bellevue

SURFACE WATER UTILITY

TITLE

DETENTION POND