

OFFSET FRAME SO THAT TEE IS VISIBLE AT EDGE OF OPENING AND DIRECTLY OVER THE STEPS

FRAME AND GRATE OR RING AND COVER

MAX. DESIGN WSE

STRAP TO WALL. 2 STRAPS MIN. REQUIRED.

1/2 D MAX.

INLET PIPE

OUTLET PIPE

D=18" MAX.

T-SECTION

**NOTES:**

1. ALL METAL PARTS AND SURFACES MUST BE MADE OF CORROSION RESISTANT MATERIAL OR GALVANIZED.

OUTLET PIPE DIA.	STRUCTURE TYPE
12"	TYPE 2 CB-48"
18"	TYPE 2 CB-54"



**City of Bellevue**

SURFACE WATER UTILITY

TITLE

SPILL CONTROL (SC) SEPARATOR  
TYPE 2

NO. D-43