


ELEVATION VIEW



PLAN VIEW

NOTES:

1. NEOPRENE GASKETS REQUIRED AT ALL CMP AND CPE PIPE JOINTS.
2. 36" MINIMUM PIPE DIAMETER. WHERE DIAMETER IS LESS THAN 60", OMIT ACCESS RISERS AND PROVIDE TYPE 2 CATCH BASIN AT EACH END OF PIPE (MAXIMUM SPACING SHALL BE 100 FEET).
3. ALL METAL PARTS SHALL BE CORROSION RESISTANT. STEEL PARTS SHALL BE GALVANIZED AND ASPHALT COATED (TREATMENT 1 OR BETTER).
4. CAPACITY OF OUTLET PIPE MUST BE EQUAL TO OR GREATER THAN ALL INLET PIPES COMBINED.
5. ACCESS RISERS REQUIRED CENTERED OVER EVERY 100' OF DETENTION PIPE WITH TYPE 2 CATCH BASINS PROVIDED ON EACH END. ADDITIONAL ACCESSES ARE REQUIRED FOR EVERY 50 ADDITIONAL FEET OF DETENTION PIPE.
6. IN AREAS WITH VEHICULAR TRAFFIC, PROVIDE TRAFFIC BEARING ACCESS (HS-20) OVER CORRUGATED METAL MANHOLE, PER STANDARDS.



City of
Bellevue

SURFACE WATER UTILITY

TITLE

RUNOFF TREATMENT OR COMBINED
(WET OR WET/DRY)
DETENTION PIPE