

# **Bellevue Building Code**

**Amendment Insert Pages  
to the  
2012 Edition  
of the  
UPC**



**1101.11.2.2(B) Combined System.** The secondary roof drains shall connect to the vertical piping of the primary storm drainage system conductor downstream of any horizontal offset below the roof. The primary storm drainage system shall connect to the building storm water that connects to an underground public storm sewer. The combined secondary and primary roof drain systems shall be sized in accordance with Section 1106.0 based on double the rainfall rate for the local area. A relief drain shall be connected to the vertical drain piping, within 20 feet of grade, using a wye-type fitting piped to daylight on the exterior of the building. The piping shall be sized as required for a secondary drain with a 4 inch maximum.

INTENTIONALLY LEFT BLANK

(INSERT FACING PAGE 139)